


Installation/Anschluss
 Installation/Raccordement
 Installation/Connection

SMA

Installationsanleitung_SMA_REV0_25_02_2013.pdf




V	9 ~ 60VDC			
	Start-up current: < 22mA Courant de démarrage: < 22mA			
	Red	3mA	5mA	10mA
	Green	3mA	5mA	10mA
	Amber	3mA	5mA	10mA
	White	3mA	5mA	10mA
	Blue	6mA	10mA	20mA

	$0.5\text{mm}^2 \sim 2.5\text{mm}^2$	
	-10°C ~ +55°C	
	FR ABS & Polycarbonate Translucent	
	S IP 21C	D IP 33C
	1 Hz	

WARNING:
 Do NOT use high voltage testers if ANY equipment is connected to the system.
ATTENTION:
 Ne PAS utiliser de testeurs haute tension lorsqu'un équipement est connecté au système.


CE





(i) Earth screen must be continuous along entire length of loop.
 (ii) Option: l'ensemble du câble peut être protégé par écran.

Switches settings Interrupteurs		1	2	3	4
		2P	Cont	M	H

		Switches/Interrupteurs			
Flash rate	Continuous	0	0		
	1Flash	1	1		
	2Flash	0	1		
Current setting	Low			1	1
	Medium			0	1
	High			1	0



Care should be taken to ensure the cable does not put stress on the circuit board.

Veuillez vous assurer que le câble ne crée pas de pression sur le circuit imprimé.



Lebensgefahr durch elektrischen Strom! Dieses Gerät darf nur durch autorisierte Elektrofachkräfte und elektrotechnisch unterwiesene Personen montiert und angeschlossen werden.
Electric current! Danger to life! Only authorized or instructed persons may assemble and install this device.
Tension électrique dangereuse! Seuls les personnes averties sont autorisées d'assembler et d'installer ces produits.